

LOCATION 627 Derby Ct. CITY Castonia

BETWEEN Downey Ave. STREET & Bridle Path STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>8'</u>		<u>Tied over 90' of ext</u>	
MAIN TO PROP. LINE				<u>4-22-94</u>	<u>3/4 plastic to ext 4"</u>	
PROP. LINE TO BLDG.					<u>plastic main</u>	

ENTERS: 627 Derby Ct BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By EP

MAIN-SIZE 4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. 6 In. LOCATION \_\_\_\_\_


"A" P/S READING P TOTAL ANODES 1# 17 # \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY