

LOCATION 4405 Derry Down Ln. CITY Gastonia

BETWEEN Cove Creek Dr STREET & Farmbrook Dr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>111'</u>	<u>1-30-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>35'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>76'</u>			

ENTERS: 4405 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 271' S.W. of center of
Cove Creek Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY Stuff Smith

MAIN-SIZE 2' C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 15' SE of center of Derry Down Ln.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 56687

REMARKS:

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	S	
	P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY