

LOCATION 4414 Derry Down Ln CITY Bastonia

BETWEEN Farmbrook Cir. STREET & Cove Creek Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>71</u>	<u>6-2-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>66'</u>			

ENTERS: 4414 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 600 PSI _____ INCHES W.C. LOCATION 98' E of center of

Farmbrook Cir.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HARTGREN

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 16' S. of center of Derry Down Ln

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 402677

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY