

LOCATION 604 Devonwood Ct. CITY GASTONIA  
BETWEEN Myrtlewoods Dr. STREET & End of Culdesack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>30'</u>	<u>6-5-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>25'</u>			

ENTERS: 600 BRANCHED INTO: 604  
TAP SIZE: 3/4 straight plastic Tee PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 99' E of C of Devonwood Ct.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

~~MAIN~~ SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 2 FT. 0 IN. LOCATION 337' N of C of Myrtlewoods Dr.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 336660

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY