

LOCATION 615 Devonwood Ct.CITY GastoniaBETWEEN Myrtlewood dr.STREET & Lead Ensl

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	76'	2-8-95		
MAIN TO PROP. LINE	11	11	7'			
PROP. LINE TO BLDG.	11	11	63'			

ENTERS: 615BRANCHED INTO: —TAP SIZE: 1/2


PRESSURE

P.S.I.

INCHES W.C.

LOCATION 42' W. of Cap  
Devonwood Ct.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By JPMAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1992DEPTH: 3 Ft. 0 In. LOCATION"A" P/S READING P TOTAL ANODES 1\* — 17\* — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY