

LOCATION 805 Dewey ST CITY CASTONIA

BETWEEN Eighth ST STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>63'</u>	<u>3-18-95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>53'</u>			

ENTERS: 805 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 217' S. of center of Eighth ST


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFELMAN

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1990

DEPTH: 3 Ft. In. LOCATION 14' W. of center of Dewey ST

"A" P/S READING P TOTAL ANODES 1* 17 * 0 L.R. # 122258

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY