

LOCATION 600 Diane Theater Rd. CITY GASTONIA
BETWEEN U.S. 74 STREET & OATES Rd. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>47'</u>	<u>11-25-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>20'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>27'</u>			

ENTERS: 560 BRANCHED INTO: 600
TAP SIZE: 3/4 P-Tee PRESSURE 600 PSI _____ INCHES W.C. LOCATION 1747' S of C of OATES Rd.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
~~Service~~ MAIN SIZE 3/4 C.I. _____ BARE STEEL ✓ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 11-18-83
DEPTH: 2 FT. 0 IN. LOCATION 199' E of C of Diane Theater Rd.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # N/A

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY