


LOCATION 200 S. Dixie ST CITY GASTONIABETWEEN Adam ST STREET & Parkdale ST STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	96'	1-17-95		
MAIN TO PROP. LINE	3/4"	P	0			
PROP. LINE TO BLDG.	3/4"	P	96'			

ENTERS: 200 BRANCHED INTO:TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 89' E. of center ofS. Dixie STPRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HuffstetterMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1965DEPTH: 3 Ft. In. LOCATION 14' S. of center of Adam ST"A" P/S READING .7 TOTAL ANODES 1\* 1 17\* 0 L.R. # 11646

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY