

LOCATION 130 Dixon Circle CITY Orlando
BETWEEN Dixon Circle STREET & S. Marietta STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C/W</u>	<u>7'</u>			
MAIN TO PROP. LINE				<u>Relocated 2-16-98</u>		
PROP. LINE TO BLDG.						

ENTERS: 159 Dixon Circle BRANCHED INTO: 130 Dixon Circle
TAP SIZE: 3/4 PRESSURE 20 P.S.I. _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 psi For 44 Hrs. By EP
MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED _____
DEPTH: 1 Ft. 6 In. LOCATION _____

"A" P/S READING .85 TOTAL ANODES 1# Q17 # 0 L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>Lead</u>	<u>.85</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY