

LOCATION 146 Dixon Circle CITY SANTAMIA  
BETWEEN S. Marietta St. STREET & Winget Cir. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>75'</u>	<u>3-6-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>30'</u>			
PROP LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>45'</u>			

ENTERS 135 Dixon Circle BRANCHED INTO: 146 Dixon Circle  
TAP SIZE 3/4 3WAY PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 376' NE of Cap Dixon Circle  
Plastic Tee

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL


Service SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1-20-89

DEPTH: 2 FT 0 IN. LOCATION 14' SW of Cap Dixon Circle

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # \_\_\_\_\_

REMARKS.

\* No Main Available Split Service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

COPY