

LOCATION 214 Dixon Cir. Apt. A + Apt. B

CITY Gastonia

BETWEEN Dixon Cir. [100 Block]

STREET & S. Marietta St.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.						
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE: PRESSURE _____ PSI _____ INCHES W.C. LOCATION

PRESSURE TEST: @ _____ PSI FOR _____ HRS BY _____

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1960


DEPTH: 3' FT. 0 IN. LOCATION Dixon Cir. [200 Block]

"A" P/S READING 1.052 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: 214 Apt. A + B: Bonded insulated 3/4" C+I service tee to 2" C+I gas main.
Apt. A: Reading: .716 before bond and .972 after bond.

Apt. B: Reading: .650 before bond and 1.039 after bond.

C.P. # 1845



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY