

LOCATION 214 Dixon Cir. Apt. A + Apt. B

CITY Gastonia

BETWEEN Dixon Cir. [100 Block]

STREET &amp; S. Marietta St.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.						
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE:

PRESSURE \_\_\_\_\_ PSI

\_\_\_\_\_ INCHES W.C.

LOCATION \_\_\_\_\_

PRESSURE TEST: @ \_\_\_\_\_ PSI FOR \_\_\_\_\_ HRS. BY \_\_\_\_\_

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1960

DEPTH: 3' FT. 0 IN. LOCATION Dixon Cir. [200 Block]


"A" P/S READING 1.052

TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: 214 Apt. A: + B.: Bonded insulated 3/4" C+W service, tie to 2" C+W gas main.  
Apt. A: Reading: .716 before bond and .972 after bond.

Apt. B: Reading: .650 before bond and 1.039 after bond.

C.R. # 1845



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY