

LOCATION 400 W. Dixon St CITY Gastonia  
BETWEEN S. York Rd STREET & Deadend STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PL</u>	<u>159'</u>		<u>2</u>	<u>12-98</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>43'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>116'</u>			

ENTERS: 400 BRANCHED INTO: —  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SE  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997  
DEPTH: 3 FT. 8 IN. LOCATION \_\_\_\_\_

"A" P/S READING PL TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Risen</u>	<u>PL</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY