

LOCATION 604 Dogwood Pl CITY Castroville
BETWEEN Oakwood Cir STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>107'</u>	<u>6-9-00</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>15'</u>			
PROP LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>92'</u>			

ENTERS: 604 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 40 PSI INCHES WC LOCATION 187' S. of center of
Oakwood Cir.

PRESSURE TEST @ 100 PSI FOR 4 HRS BY S.H.
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998
DEPTH: 3 FT 0 IN LOCATION 13' E of center of Dogwood Pl.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 517060

REMARKS:

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>S</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>	