

LOCATION 807 S Dogwood CITY Gastonia  
BETWEEN 8<sup>th</sup> STREET & Garrison STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>9</u>	<u>101'</u>			<u>11-10-97</u>
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>95'</u>			

ENTERS: 807 BRANCHED INTO: 0  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 191' N of c of 8<sup>th</sup>


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BC

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. IN. LOCATION 20' W of c of Dogwood

"A" P/S READING plastic TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>AR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY