

LOCATION: 902 Dogwood CITY Gastonia
BETWEEN Eighth St. STREET & Dogwood STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>68'</u>	<u>Tied over 1-7-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>1</u>	<u>Exist service</u>		
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>67</u>	<u>to new 2' pkstee</u>		


ENTERS: 902 Dogwood BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 18' north of Dogwood
142' East of Eighth St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY m.p.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 6 IN. LOCATION 18' north of Dogwood

"A" P/S READING plastic TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Tied Exist. service to new main

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic riser</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		