

LOCATION 912 Dogwood CITY Gastonia
BETWEEN Eighth St. STREET & Dogwood STREET


	SIZE	TYPE	<u>912</u> LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>101'</u>	<u>Tied over</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>1'</u>	<u>Exist Service</u>		
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>106'</u>	<u>to new 2" Plastic</u>		

ENTERS: 912 Dogwood BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 18' north of Dogwood
314' East of Eighth St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M.P.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1992
DEPTH: 3 FT. 6 IN. LOCATION 18' north of Dogwood

"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Tied Exist Service to new main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Plastic Piger</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY