

LOCATION 7006 Dolphin St CITY Gastonia
BETWEEN Marlin St STREET & S. New Hope Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>70'</u>	<u>4-16-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>65'</u>			

ENTERS 7006 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 97' SW of center of Marlin St

PRESSURE TEST @ 100 PSI FOR 4 HRS BY SLH
MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2002
DEPTH 3 FT 0 IN LOCATION 19' S of center of Dolphin St

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 80693

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

