

LOCATION 7010 Dolphin st. CITY Gastonia N.C.
BETWEEN S. New Hope Rd. STREET & Marlin st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>61'</u>	<u>11.20.01</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>56'</u>			

ENTERS 7010 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES WC LOCATION W. side of 7010

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY T. Cain
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC / YEAR INSTALLED 2001
DEPTH 3 FT IN LOCATION S. side of Dolphin st.

"A" P/S READING N/A TOTAL ANODES 1# 17# L.R. #
REMARKS

