

LOCATION 1031 Dornach Dr. CITY DASTONIA
BETWEEN Heatherloch Dr. STREET & End of Caldesack STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>170'</u>	<u>12-21-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>15'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>155'</u>			

ENTERS: 1031 BRANCHED INTO: 0
TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 300' N of Cof Heatherloch Dr.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1973
DEPTH: 3 FT. 0 IN. LOCATION 16' E of Cof Dornach Dr.

"A" P/S READING 1.0 TOTAL ANODES 1# _____ 17# _____ L.R. # 648480

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Rise PLASTIC</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		