

LOCATION 1235 DORSET DR. CITY CATAMUN

BETWEEN NOTTINGHAM DR. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	86'	4-24-00		
MAIN TO PROP. LINE	3/4"	P	40'			
PROP. LINE TO BLDG.	3/4"	P	46'			

ENTERS: 1235 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 17' S. of center of NOTTINGHAM DR.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S.H.

MAIN-SIZE 4" C.I.  BARE STEEL  COATED STEEL ✓ PLASTIC  YEAR INSTALLED 1969

DEPTH: 3 FT 0 IN LOCATION 88' E. of center of DORSET DR.

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 L.R. # 340810

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	