

LOCATION 2112 Dove Tree Ln. CITY GASTON
BETWEEN 2nd St. STREET & Warren STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>32'</u>	<u>Replaced 7-17-95</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 2112 2nd St BRANCHED INTO: 2112 Dove Tree
TAP SIZE: 3/4" S PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 psi For 14 Hrs. By EP
MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995
DEPTH: 2 Ft. 0 In. LOCATION _____

"A" P/S READING 1.0 TOTAL ANODES 1# 1 17# _____ L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R.S.</u>	<u>1.0</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY