

LOCATION 121 Dove Wood Lane CITY GASTONIA
BETWEEN Harper Rd. STREET & Dove Wind Ct. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>100'</u>	<u>10-12-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>144'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>56'</u>			

ENTERS: 121 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 487' w of 1st Dove Wind Ct.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1988
DEPTH: 3 Ft. 0 In. LOCATION 18' S of 1st Dove Wood Ln.

"A" P/S READING Plastic TOTAL ANODES 1* _____ 17* _____ L.R. # 431 419

REMARKS: New 3/4 Plastic Gas Service with A Road Bore.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY