

LOCATION 1616 Drayton Ct. CITY Gastonia
BETWEEN Drayton Hall Ct STREET & Carl-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>54'</u>	<u>3-8-00</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>49'</u>			

ENTERS: 1616 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 121' W. of center of Drayton Hall Ct.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS. BY S.H.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1988

DEPTH: 3 FT 0 IN. LOCATION 44' N. of center of Drayton Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 179748

REMARKS:

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

