

LOCATION 3068 Drayton Hall Way CITY CAROLINA
BETWEEN Drayton CT STREET & Cal-de-Sue STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>77'</u>	<u>5-16-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>7'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>70'</u>			


ENTERS: 3068 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 169' S. of center of
Drayton CT.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HALL 8/24
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED _____

DEPTH: 3 FT. 0 IN. LOCATION 35' W. of center of Drayton Hall Way

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 275297

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY