

LOCATION 1125 Dumbarton Rd CITY Las Vegas

BETWEEN Dorset STREET & Lancel Lane STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	65	4-18-94		
MAIN TO PROP. LINE	3/4	"	5			
PROP. LINE TO BLDG.	3/4	"	60			

ENTERS: 1115 BRANCHED INTO: 1125

TAP SIZE: 3/8 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Side of house


PRESSURE TEST: @ 100 psi For 44 Hrs. By Bennett

MAIN-SIZE 3/4" Ser C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 1 Ft. 6 In. LOCATION Side of 1115

"A" P/S READING 60 TOTAL ANODES 1# 1 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY