

LOCATION 502 Dunham Rd. CITY GASTONIA
 BETWEEN Armstrong Park Rd. STREET & Scottwood STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>114'</u>	<u>6-5-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>84'</u>			

ENTERS: 502 BRANCHED INTO: 0
 TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 110' S of C of Scottwood.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
 MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993
 DEPTH: 3 FT. 0 IN. LOCATION 12' w of C of Dunham Rd.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 282487

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY