

LOCATION 504 Dunham Rd.CITY GastoniaBETWEEN scottwoodSTREET & Armstrong Park

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>cw</u>	<u>- 2 -</u>	<u>TIED OVER</u> <u>4-16-94</u>		
MAIN TO PROP. LINE				<u>98' EXIST 3/4" cw</u>		
PROP. LINE TO BLDG.				<u>original 8-21-92</u>		


ENTERS: 504

BRANCHED INTO:

TAP SIZE: 1/2PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C.LOCATION 15' W ofDunhamPRESSURE TEST: @ 100 psi For 1/4 Hrs. By M ParkerMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 90DEPTH: 3 Ft. 0 In.LOCATION 129' S of scottwood."A" P/S READING .95TOTAL ANODES 1# 1 17# \_\_\_\_\_

L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>.95 cw</u> <u>RISER</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY