

LOCATION 2342 Eagle CKN CT CITY Easton

BETWEEN FALCON Nest STREET A STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>98</u>	<u>8-23-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>140</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>58</u>			

ENTERS: 2342 BRANCHED INTO 2

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W C LOCATION


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY ER

MAIN SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH 3 FT 6 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# 17 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volt
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

[Handwritten signature]