

LOCATION 2351 Eagle Glen CT CITY GASTON, N.C.
 BETWEEN FALCON'S NEST CT STREET & Cut-off St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>74'</u>	<u>6-14-99</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>48'</u>			

ENTERS: 2351 BRANCHED INTO:
 TAP SIZE: 3/4" PRESSURE 40 PSI INCHES W.C. LOCATION 593' N. of center of Falcon's Nest CT


PRESSURE TEST: @ 100 PSI FOR 44 HRS BY SM

MAIN SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998

DEPTH: 3 FT 0 IN LOCATION 19' W. of center of Eagle Glen CT

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 474928

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>R</u>	