

LOCATION 2398' Eagle Glen CITY Gastonia

BETWEEN Falcons Nest STREET & Dead End STREET.

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>101</u>	<u>7-6-98</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>41</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>60</u>			

ENTERS: 2398 BRANCHED INTO: 0

TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 104' N of c of Falcons Nest


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BC

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. IN. LOCATION 17' w of c of Eagle Glen

"A" P/S READING plastic TOTAL ANODES 1# - 17# - L.R. # 477592

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>8 R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY