

LOCATION 312 EAGLEWALK DR. CITY CANTONIA

BETWEEN Bounty Line STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>124'</u>	<u>7/7/95</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>34'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>96'</u>			

ENTERS: 312 BRANCHED INTO: \_\_\_\_\_

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By SP

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1981

DEPTH: 3 Ft. 6 In. LOCATION 325' N of C of Bounty Ln 13' W. of C of Eaglewalk

"A" P/S READING P TOTAL ANODES 1\* 1 17\* P L.R. # 00322505

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY