

LOCATION 3618 East Hampton Ct. CITY GASTONIA
BETWEEN Kennedy Rd. STREET & Trabert Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>85'</u>	<u>2-7-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>75'</u>			

ENTERS: 3618 BRANCHED INTO: 3612
TAP SIZE: 1/2 PRESSURE 600 PSI _____ INCHES W.C. LOCATION 274' S of C of Kennedy Rd.


PRESSURE TEST: @ 100 PSI FOR 4 HRS. BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 FT. 6 IN. LOCATION 20' N of C of East Hampton Ct.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 066479

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Rise Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY