

LOCATION 3637 Easthampton Rd CITY GASTONIA

BETWEEN Kennedy Rd STREET & Trebut Ct STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>21'</u>	<u>5-16-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>13'</u>			

ENTERS: 3637 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 68' E. of center at

Easthampton Rd.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HUFFSTAL

MAIN-SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 2 FT. 0 IN. LOCATION 307' N. of center at Trebut Ct

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 308022

REMARKS:

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	S		
P/S Pipeline Lead - White Existing Main	E		

