

LOCATION 3666 Easthampton Dr. CITY Easton Va

BETWEEN Trabert Cr. STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>62'</u>	<u>9-7-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>50'</u>			

ENTERS 3666 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 50' SW. of center of Trabert Cr.


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY Sith

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993

DEPTH 3 FT 0 IN LOCATION 19' NW. of center of Easthampton Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 839832

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	