

LOCATION 4345 East Ridge Dr. CITY Gastonia
BETWEEN Wood Field Cir STREET & Harper Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>132</u>	<u>11/2/00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>32</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>100</u>	<u>"</u>		

ENTERS 4345 East Ridge Dr. BRANCHED INTO ⊖

TAP SIZE 1/2" PRESSURE 60 PSI INCHES W C LOCATION 143 Ft south of center of Wood Field Cir


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3' FT 0" IN LOCATION 12 FT EAST OF E. East Ridge Dr.

"A" P/S READING TOTAL ANODES 1# 0 17# 0 L.R. # 01002891

REMARKS: new plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>