

LOCATION 4362 Eastridge DR CITY BASTONIA  
BETWEEN FIRMIN CT STREET & HARPER RD STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>74'</u>	<u>9-26-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>64'</u>			

ENTERS: 4362 BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 241' W. OF center  
of Firmin CT

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huff-Stettin  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1996  
DEPTH: 3 Ft. 0 In. LOCATION 12' N. of center of Eastridge DR

"A" P/S READING P TOTAL ANODES 1\* 0 17\* 0 L.R. # 530819

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY