

LOCATION 4381 EASTRIDGE DR CITY COLUMBIA  
 BETWEEN HARPER RD STREET & FLEMING RD STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>115'</u>	<u>12-8-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>42'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>73'</u>			


ENTERS 4381 BRANCHED INTO 0  
 TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 340' E OF C OF  
HARPER RD

PRESSURE TEST @ 100 PSI FOR 48 HRS BY RR

MAIN SIZE 2" C I        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1996  
 DEPTH 3 FT 0 IN LOCATION 12' S OF C OF EASTRIDGE DR

"A" P/S READING Plastic TOTAL ANODES 1# 0 17# 0 LR # 01112282

REMARKS  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>dark</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>light</u>