


LOCATION 516 EAST wood Dr.CITY BASTOWIABETWEEN GARDNER PARK D.I.STREET & Club Dr.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>6'</u>	<u>4-23-94</u>	<u>Tied over 114' Existing</u>	
MAIN TO PROP. LINE					<u>3/4 CFW</u>	
PROP. LINE TO BLDG.						

ENTERS: 516BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 327' W of C of Club Dr.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RLMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1993DEPTH: 3 Ft. 0 In. LOCATION 14' S of C of EAST wood Dr."A" P/S READING P TOTAL ANODES 1\* 1 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_REMARKS: Reading went to .95 After Anode. Reading was .04  
Bonded Dresser. Tied Trace wire OFF AT Tee**Bare Main Replacement  
Program**

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser .95</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

**ENG. DEPT. USE ONLY**