


LOCATION 556 EASTWOOD Dr.CITY CASTONIABETWEEN GARDNER PARK Dr.STREET & FLANAGAN LANE

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>0'</u>	<u>5-7-94</u>	<u>Tied over</u>	<u>103' Existing</u>
MAIN TO PROP. LINE					<u>3/4 PLASTIC</u>	
PROP. LINE TO BLDG.						

ENTERS: 556BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 430' W of C of FLANAGAN LANEPRESSURE TEST: @ 100 psi For 14 Hrs. By RLMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1993DEPTH: 3 Ft. 0 In. LOCATION 14' S of C of EASTWOOD Dr."A" P/S READING P TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY