

LOCATION 559 Eastwood Dr. CITY GASTONIA
BETWEEN FLANNAGAN STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>con</u>	<u>105'</u>	<u>7/20/92</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>Plastic</u>	<u>6'</u>	<u>4/30/94</u>		
PROP. LINE TO BLDG.						

ENTERS: 559 BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION North side of 559

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992
DEPTH: 3 Ft. 0 In. LOCATION East side of Eastwood Dr.

"A" P/S READING 1.20 TOTAL ANODES 1# _____ 17# 0 L.R. # _____

REMARKS: Tied over 105' of 3/4" con service to new
main with 6' of 3/4" Plastic Pipe



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>1.20</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY