

LOCATION 625 Eastwood Dr

CITY EASTONIA

BETWEEN Gardner Park Dr.

STREET &amp; FLANAGAN Lane

STREET

Renewed Service	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	<del>RENEWED</del>
MAIN TO BLDG.	3/4	P	125'	5-7-94	152' Existing	3/4 Bare
MAIN TO PROP. LINE	3/4	P	5'		Service	Pipe
PROP. LINE TO BLDG.	3/4	P	120'			

ENTERS: 625

BRANCHED INTO: 637

TAP SIZE: 3/4 Straight Tee

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION 537' N of Cof Gardner Park Dr.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 3/4 C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 3 Ft. 0 In. LOCATION 13' E of Cof Eastwood Dr.

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY