

LOCATION 634 Eastwood Dr.CITY EASTONIABETWEEN Bardner Park Dr.STREET & Flanagan Lane

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>	<u>5-7-94</u>	<u>Tied over 130' Existing</u>	
MAIN TO PROP. LINE					<u>3/4 CHW</u>	
PROP. LINE TO BLDG.						

ENTERS: 634BRANCHED INTO: 0TAP SIZE: 1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

550' w of Cor Bardner Park Dr.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RLMAIN-SIZE 2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1993DEPTH: 3

Ft.

0 In.

LOCATION

13' w of Cor Eastwood Dr.

"A" P/S READING


P

TOTAL ANODES 1\*

1

17\*

L.R. #

REMARKS: Bonded Dresser, Tied Trace wire OFF At Tee

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser 1.65
P/S Pipeline Lead - White Existing Main	E	Read .65 5-7-94

ENG. DEPT. USE ONLY

Reading Came  
up AFTER Anode  
HAD time to work

Reads 6.65  
8-24-94 Thanks RDL