

LOCATION 637 Eastwood Dr. CITY OASTONIA
BETWEEN Gardner Park Dr. STREET & FLAWAGAN STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>38'</u>	<u>5-7-94</u>	<u>Tied over</u>	<u>153' Existing</u>
MAIN TO PROP. LINE					<u>3/4 CFW</u>	
PROP. LINE TO BLDG.						

ENTERS: 637 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 540' N of C of Gardner Park Dr.


PRESSURE TEST: @ 100 psi For 14 Hrs. By RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 13' W of C of Eastwood Dr.

"A" P/S READING _____ Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Banded Dresser, Tied Trace wire off at Tee



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser .95
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY