

LOCATION 655 Eastwood Dr. CITY San Antonio

BETWEEN Anders Dr. STREET & Flanagan STREET

	SIZE	TYPE	S	LENGTH	P	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	PIPE	136	3		Tied over 4-30-94		
MAIN TO PROP. LINE	3/4		33	3				
PROP. LINE TO BLDG.	3/4		103	0				

ENTERS: 655 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Trailer house

PRESSURE TEST: @ 100 psi For 114 Hrs. By Bennett

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1993


DEPTH: 2 Ft. 6 In. LOCATION 15' w/cy 81

"A" P/S READING .55 TOTAL ANODES 1# 1 17# _____ L.R. # _____

REMARKS:

Bare Main Replacement

Bare Main Replacement Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	1020
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY