

LOCATION 2009 Echo Ln.CITY GASTONIABETWEEN Hudson Blw.


STREET &amp;

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Steel</u>	<u>8'</u>	<u>Replaced 10-2097</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 2009

BRANCHED INTO:

TAP SIZE 3/4 Ser. PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION \_\_\_\_\_PRESSURE TEST: @ 100 PSI FOR 164 HRS BY EPMAIN-SIZE 3/4 C I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_DEPTH: 1 FT 6 IN LOCATION \_\_\_\_\_"A" P/S READING 1.3 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_REMARKS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>1.3</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY