

LOCATION 2024 Echo Ln. CITY GASTON, N.C.

BETWEEN Hudson Blvd. STREET & Dead End. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3 1/4"</u>	<u>P</u>	<u>114'</u>	<u>4-17-98</u>		
MAIN TO PROP. LINE	<u>3 1/4"</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3 1/4"</u>	<u>P</u>	<u>74'</u>			

ENTERS: 2024 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 419' S. of center of

Hudson Blvd


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS BY S. Hultshuler

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 3 FT 0 IN LOCATION 20' W. of center of Echo Ln.

"A" P/S READING 1.1 TOTAL ANODES 1# 0 17# 0 L.R. # 261014

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main.	E	

ENG. DEPT. USE ONLY