

LOCATION 1120 Edgemont Ave CITY GASTONIA
BETWEEN FAIRFIELD DR. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	C&W Plastic	42' 3'	Tied over 6/11/04		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1120 BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION NE side of 1120


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. — In. LOCATION SW side of FAIRFIELD DR

"A" P/S READING .60 TOTAL ANODES 1* 1 17* 0 L.R. #

REMARKS: Tied over 42' of ex 3/4" C&W service to new
Plastic main with 3' of 3/4" Plastic Pipe



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R	1.50
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY