

LOCATION 1121 & 1119 & 1119 1/2 Edgemont Dr.CITY GASTONIABETWEEN Fairfield Dr.

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>C&W Plastic</u>	<u>63'</u> <u>209'</u>	<u>6/18/94</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						


ENTERS: 1121 & 1119 & 1119 1/2

BRANCHED INTO:

TAP SIZE: <u>1/2"</u>	PRESSURE <u>60</u> P.S.I.	INCHES W.C.	LOCATION <u>E Side of 1121</u> <u>W Side of 1119 1/2</u> <u>S Side of 1119</u>
-----------------------	---------------------------	-------------	--

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DTMAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC — YEAR INSTALLED 1992DEPTH: 3 Ft. — In. LOCATION East side of Edgemont Ave"A" P/S READING 1.70 TOTAL ANODES 1* 1 17* 0 L.R. # —

REMARKS: Tied over 63' of Ex 3/4" C&W ser to new main with 56' of 3/4" Plastic pipe
31' of Ex 3/4" Plastic ser & 122' of Ex 3/4" Plastic ser to 1119 & 1119 1/2 split
with ser to 1121. The 1.6 PS Reading was taken after anode installed



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>1121</u> <u>R</u>	<u>1.60</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY