

LOCATION 1122 EdgemontCITY GASTONIABETWEEN Fairfield


STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>Transition</u>	<u>tic over</u>	<u>Existing</u>	
MAIN TO PROP. LINE				<u>154 C+L</u>	<u>Retired 34' of Service</u>	
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 150 West of FairfieldPRESSURE TEST: @ 100 psi For 1/4 Hrs. By K HayesMAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993DEPTH: 3 Ft. _____ In. LOCATION 12 South of center of Edgemont"A" P/S READING 1.1 TOTAL ANODES 1# 1 17# _____ L.R. # _____REMARKS: Tracer wire Not Banded
Ins. jumped

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY